## thePassa P360 DALI-2 S UP WH







?? ???? : 2010390 ????? ???? ???? ????? ??? ?????? DALI-2 ????? ??? : 360 ???? ????? ??? : 2-6 ??? 10-10000 lx : ?????? ???? P 54: ???? ?????

???? ???? ???? ???? ???? ????

<u>?? ???? ?????? ??? ????? ??????</u>

???

## **Function description**

- Passive infra-red presence sensor for flush-mounted ceiling installation, DALI-2 certified
  - Rectangular detection area 360°, 30 x 4,5 m, (135 m<sup>2</sup>) •

at mounting height 3 m, for corridors and storage

areas, with 2 individually connectable and disconnectable detection zones

- This device provides information about presence and brightness in the form of a DALI telegram in line with IEC 62386 Part 303/304
  - 3 instances for presence detection area zone 1 + 2 / zone 1 / zone 2
    - 2 mixed light measurements •

- 3 instances for brightness detection area zone 1 + 2 / zone 1 / zone 2
  - Easy to calibrate brightness measurement •
  - Test mode for checking function and detection area
    - Configurable detection sensitivity •
    - Can be configured via DALI bus or remote control •
- The "theSenda S" or "theSenda B" user remote controls can be used to dim or switch the lamps, to control the blinds, or to execute additional functions via the higher-level control
  - Ceiling installation in flush-mounted box •
  - Surface-mounted installation possible with surface frame 110A (optional)
    - Area restriction with cover clips (optional) •
  - "theSenda B" app remote control (optional) and corresponding "theSenda Plug" app (for iOS/Android) •
- A Multi-Master Application Controller is required for commissioning/control and configuration. According to IEC 62386, this must include parts 101/103 and optionally 301/303/304

// //